



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
13296-52-4477
State Number
23181

EQUIPMENT INSPECTED

State Number: 23181	Type of Unit: Passenger	Floor to Floor: 1 to 4
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 125
Landings: 4	Installed: 09/21/2005	Rope Size: 3/8"
Volts: 208	Complied: 09/23/2005	Entrances: 1
OWNER		OCCUPANT
49 BROADWAY ARTS CONDOMINIUM ASSOC.		49 BROADWAY ARTS CONDOMINIUMS
12 1/2 WALL STREET / SUITE "D"		49 BROADWAY AVE.
ASHEVILLE, NC, 28801		ASHEVILLE, NC, 28801

INSPECTION INFORMATION

Inspection Date 10/23/2013	Type Inspection Routine	Certificate Status Re-issued	Inspector 52 - Sosebee	County BUNCOMBE	11 B
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------	------

VIOLATIONS

2.27.1.1.2	Put the in car emergency telephone in proper working order. Phone worked. Turn up volume.
2.14.7.1.3	Put the in car emergency light in working order.
8.11.2.2.2	Perform an annual no load safety test and provide proper tags.
8.6.1.7.2	Provide proper metal tag to the controller for all periodic tests.

Items must be corrected by: 11/22/2013

Elevator Name: ELEVATOR # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: John Ball 828-337-6983

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

49 BROADWAY ARTS CONDOMINIUM ASSOC.
12 1/2 WALL STREET / SUITE "D"
ASHEVILLE, NC, 28801