N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
13297-48-3917
State Number
24167

EQUIPMENT INSPECTED

State Number: **24167**	Type of Unit: Passenger	Floor to Floor: 1 to 5
Capacity: 2500	Manuf: SCHINDLER	Speed: 125
Landings: 5	Installed: 02/28/2007	Rope Size: 0
Volts: 208	Complied: 03/01/2007	Entrances: 1

OWNER	OCCUPANT
CAMS	THE PRESERVE, BLDG #3, CAR #3
1630 MILITARY CUTOFF RD.	3100 MARSH GROVE LANE
WILMINGTON, NC, 28403	OAK ISLAND, NC, 28465

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County	
10/24/2013	Routine	Re-issued	48 - Martin	BRUNSWICK	10

VIOLATIONS

2.7.5.1	Put the machine room lights in working order.
8.6.8.9	Signs. Caution signs shall be provided. Damaged or missing signs shall be replaced. [3RD. & 4TH. FLS.].
8.6.4.7.1	Clean the elevator pit.
8.11.2.2.2	Perform the annual no load safety test

Items must be corrected by: 11/23/2013

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: CALVIN

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
CAMS
1630 MILITARY CUTOFF RD.
WILMINGTON, NC, 28403