



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

### INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**13301-17-4693**  
State Number  
**13203**

#### EQUIPMENT INSPECTED

State Number: <b>13203</b>	Type of Unit: Passenger	Floor to Floor: G to 3
Capacity: 2000	Manuf: ASHEVILLE	Speed: 100
Landings: 3	Installed: 02/01/1990	Rope Size:
Volts: 480	Complied: 02/01/1990	Entrances: 1
OWNER	OCCUPANT	
ARBORETUM BUILDING	ARBORETUM BUILDING	
100 FREDRICK LAW OLMSTEAD WAY	WESLEY BRANCH RD	
ASHEVILLE, NC, 28806	ASHEVILLE, NC, 28806	

#### INSPECTION INFORMATION

Inspection Date 10/28/2013	Type Inspection Routine	Certificate Status Re-issued	Inspector 17 - White	County BUNCOMBE	11 A
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------	------

#### VIOLATIONS

- 8.6.5.5.1 Where valves and cylinders use packing glands or seals, they shall be examined and maintained to prevent excessive loss of fluid.
- 2.14.7.1.3 Put the in car emergency light in working order.

Items must be corrected by: 11/27/2013

Elevator Name: 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: nathan 8828-665-2492

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ARBORETUM BUILDING  
100 FREDRICK LAW OLMSTEAD WAY  
ASHEVILLE, NC, 28806