



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**13301-17-5094**  
State Number  
**18295**

EQUIPMENT INSPECTED

State Number: <b>18295</b>	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 135
Landings: 3	Installed: 11/16/1999	Rope Size:
Volts: 208	Complied: 11/16/1999	Entrances: 1
OWNER	OCCUPANT	
ARDENWOODS LLC	ARDENWOODS A RETIREMENT COMMUNITY	
2400 APPALACHIAN BLVD	2400 APPALACHIAN BLVD	
ARDEN, NC, 28704	ARDEN, NC, 28704	

INSPECTION INFORMATION

Inspection Date 10/28/2013	Type Inspection Routine	Certificate Status Re-issued	Inspector 17 - White	County BUNCOMBE	11 A
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------	------

VIOLATIONS

8.6.5.5.1 Where valves and cylinders use packing glands or seals, they shall be examined and maintained to prevent excessive loss of fluid.

Items must be corrected by: 11/27/2013

Elevator Name: everygreen

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: mike

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ARDENWOODS LLC  
2400 APPALACHIAN BLVD  
ARDEN, NC, 28704