



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
13301-17-5875
State Number
18294

EQUIPMENT INSPECTED

State Number: 18294	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 135
Landings: 3	Installed: 08/27/1999	Rope Size:
Volts: 208	Complied: 05/11/2001	Entrances: 1

OWNER

ARDENWOODS LLC
2400 APPALACHIAN BLVD
ARDEN, NC, 28704

OCCUPANT

ARDENWOODS A RETIREMENT COMMUNITY
2400 APPALACHIAN BLVD
ARDEN, NC, 28704

INSPECTION INFORMATION

Inspection Date 10/28/2013	Type Inspection Routine	Certificate Status Re-issued	Inspector 17 - White	County BUNCOMBE	11 A
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------	------

VIOLATIONS

8.6.5.5.1 Where valves and cylinders use packing glands or seals, they shall be examined and maintained to prevent excessive loss of fluid.

Items must be corrected by: 11/27/2013

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Michael 828-684-0041

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ARDENWOODS LLC
2400 APPALACHIAN BLVD
ARDEN, NC, 28704