



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
13301-47-5469
State Number
27268

EQUIPMENT INSPECTED

State Number: 27268	Type of Unit: Passenger	Floor to Floor: 1 to 4
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 125
Landings: 4	Installed: 11/24/2009	Rope Size:
Volts: 240	Complied:	Entrances: 2
OWNER	OCCUPANT	
18 CHURCH STREET LLC	ALTAMONT THEATER	
27 FOREST ROAD	18 CHURCH STREET	
ASHEVILLE, NC, 28803	ASHEVILLE, NC, 28801	

INSPECTION INFORMATION

Inspection Date 10/28/2013	Type Inspection Routine	Certificate Status Re-issued	Inspector 47 - Helton	County BUNCOMBE	11 B
-------------------------------	----------------------------	---------------------------------	--------------------------	--------------------	------

VIOLATIONS

n/a No violations found

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: 828 270 7747

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

18 CHURCH STREET LLC
27 FOREST ROAD
ASHEVILLE, NC, 28803