



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
13301-48-0986
State Number
20028

EQUIPMENT INSPECTED

State Number: 20028	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 106
Landings: 2	Installed: 01/07/2002	Rope Size:
Volts: 480	Complied: 02/27/2002	Entrances: 1
OWNER	OCCUPANT	
BLADEN CO BOARD OF EDUC	WEST BLADEN HIGH SCHOOL	
PO BOX 37	1600 NC HWY 410	
ELIZABETHTOWN, NC, 28327	BLADENBORO, NC, 28320	

INSPECTION INFORMATION

Inspection Date 10/28/2013	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BLADEN
-------------------------------	----------------------------	---------------------------------	--------------------------	------------------

9

VIOLATIONS

2.14.7.1.3 Put the in car emergency light in working order.

Items must be corrected by: 11/27/2013

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: J.R.

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

BLADEN CO BOARD OF EDUC
PO BOX 37
ELIZABETHTOWN, NC, 28327