



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
13301-48-1923
State Number
H1503

EQUIPMENT INSPECTED

State Number: H1503	Type of Unit: Hand Lift	Floor to Floor: 1 to 2
Capacity: 750	Manuf: SAVARIA	Speed: 25
Landings: 2	Installed: 03/22/2005	Rope Size:
Volts: 110	Complied: 04/01/2005	Entrances: 2
OWNER	OCCUPANT	
BLADEN COUNTY SCHOOLS	EAST BLADEN HS PB#1	
PO BOX 2519	5600 NC HWY 87 EAST	
ELIZABETHTOWN, NC, 28337	ELIZABETHTOWN, NC, 28337	

INSPECTION INFORMATION

Inspection Date 10/28/2013	Type Inspection Routine	Certificate Status Not Issued	Inspector 48 - Martin	County BLADEN
-------------------------------	----------------------------	----------------------------------	--------------------------	------------------

9

VIOLATIONS

n/a	Replace broken top and bottom run switchs
n/a	Repair unit to run

Items must be corrected by: 11/27/2013

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: William

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

BLADEN COUNTY SCHOOLS
PO BOX 2519
ELIZABETHTOWN, NC, 28337