



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
13304-8-2575
State Number
6830

EQUIPMENT INSPECTED

State Number: 6830	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 1500	Manuf: STHERN	Speed: 100
Landings: 2	Installed: 10/21/1970	Rope Size:
Volts: 220	Complied: 10/21/1970	Entrances: 1
OWNER	OCCUPANT	
JERRY T WARREN & ASSOC	JERRY T WARREN & ASSOC	
900 N MAIN STREET	900 N MAIN STREET	
RANDLEMAN, NC, 27317	RANDLEMAN, NC, 27317	

INSPECTION INFORMATION

Inspection Date 10/31/2013	Type Inspection Routine	Certificate Status Re-issued	Inspector 8 - Burris	County RANDOLPH
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

76

VIOLATIONS

8.6.11.3 KEEP ALL EMERGENCY KEYS ON PREMISES MACHINE ROOMS,HOISTWAY DOOR & EUD'S
8.6.4 REPLACE MISSING LIGHT COVER INSIDE ELEVATOR CAR.
8.6.4.15 RESTORE ELEVATOR EMERGENCY LIGHTS & ALARM FUNCTIONS

Items must be corrected by: 11/30/2013

Elevator Name: PASSENGER ELEV

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: JERRY WARREN 336.816.1799

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

JERRY T WARREN & ASSOC
900 N MAIN STREET
RANDLEMAN, NC, 27317