



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**13309-52-377**  
State Number  
**11158**

EQUIPMENT INSPECTED

State Number: <b>11158</b>	Type of Unit: Passenger	Floor to Floor: L to 10
Capacity: 2500	Manuf: THYSEN KRUPP	Speed: 350
Landings: 11	Installed: 09/10/1985	Rope Size: 5/8
Volts: 208	Complied: 03/24/2006	Entrances: 1
OWNER	OCCUPANT	
SUGAR TOP HOMEOWNERS	SUGAR TOP RESORT	
303 SUGAR TOP DRIVE	303 SUGAR TOP DRIVE	
BANNER ELK, NC, 28604	BANNER ELK, NC, 28604	

INSPECTION INFORMATION

Inspection Date 11/05/2013	Type Inspection Routine	Certificate Status Re-issued	Inspector 52 - Sosebee	County AVERY
-------------------------------	----------------------------	---------------------------------	---------------------------	-----------------

6

VIOLATIONS

- 8.6.4.14 Hoist way access shall be maintained. ( Top and Bottom floor switch stops elevator too low.)
- 8.6.4.13.1[f] Properly maintain hangers, tracks, door rollers, up-thrusts, and door safety retainers, where required. (Cab door missing upthrust roller. 2nd notice.)
- 8.6.5.10 The minimum car and counterweight clearances and runby shall be maintained in compliance with the applicable code when replacement suspension ropes are installed or when existing suspension ropes are shortened. ( 2nd notice.)
- 2.27.3.1.5 Provide proper operation of the phase I light on the main floor hall button panel.
- 8.6.4.1.2 Lubricate the hoist ropes.

Items must be corrected by: 12/05/2013

Elevator Name: # 3

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Sam 828-898-5226

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

SUGAR TOP HOMEOWNERS  
303 SUGAR TOP DRIVE  
BANNER ELK, NC, 28604