



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
13319-48-1233
State Number
16529

EQUIPMENT INSPECTED

State Number: 16529	Type of Unit: Special	Floor to Floor: 1 to 4
Capacity: 650	Manuf: SIDNEY	Speed: 96
Landings: 4	Installed: 04/28/1997	Rope Size: 1/2
Volts: 440	Complied: 04/30/1997	Entrances: 1
OWNER	OCCUPANT	
MURPHY BROWN	MURPHY BROWN	
255 BRYANT SWAMP RD.	255 BRYANT SWAMP RD	
BLADENSBORO, NC, 28320	BLADENSBORO, NC, 28320	

INSPECTION INFORMATION

Inspection Date 11/15/2013	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BLADEN
-------------------------------	----------------------------	---------------------------------	--------------------------	------------------

9

VIOLATIONS

2.14.1.5.1	Secure the car top emergency exit. [ALSO ADJUST EMER. EXIT SW.].
8.6.4.7.1	Clean the elevator pit.

Items must be corrected by: 12/15/2013

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: BILL

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

MURPHY BROWN
255 BRYANT SWAMP RD.
BLADENSBORO, NC, 28320