



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
13330-36-2958
State Number
17003

EQUIPMENT INSPECTED

State Number: 17003	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 135
Landings: 3	Installed: 09/24/1997	Rope Size:
Volts: 208	Complied: 09/24/1997	Entrances: 1
OWNER	OCCUPANT	
CHATEAU PROP., INC	COUNTRY SUITES BY CARLSON	
10000 TALLENT LANE	3211 WILSON DR	
HUNTERSVILLE, NC, 28078	BURLINGTON, NC, 27215	

INSPECTION INFORMATION

Inspection Date 11/26/2013	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

1

VIOLATIONS

2.14.7.1.3	Put the in car emergency light in working order.
2.27.1.1.2	Put the in car emergency telephone in proper working order. (Needs to hang up from operator)

Items must be corrected by: 12/26/2013

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Michael Garner 336-584-1115

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

CHATEAU PROP., INC
10000 TALLENT LANE
HUNTERSVILLE, NC, 28078