



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
13330-48-0926
State Number
23201

EQUIPMENT INSPECTED

State Number: 23201	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: OTIS	Speed: 100
Landings: 2	Installed: 11/17/2005	Rope Size:
Volts: 208	Complied: 11/17/2005	Entrances: 1

OWNER

CROSS CREEK LAND COMPANY
5019 CAROLINA BEACH RD.
WILMINGTON, NC, 28412

OCCUPANT

CROSS CREEK COMMONS
1105 NEW POINTE BLVD
LELAND, NC, 28451

INSPECTION INFORMATION

Inspection Date 11/26/2013	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

2.27.1.1.2 Put the in car emergency telephone in proper working order.

Items must be corrected by: 12/26/2013

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: MGMT

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

CROSS CREEK LAND COMPANY
5019 CAROLINA BEACH RD.
WILMINGTON, NC, 28412