



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
13330-7-4474
State Number
19010

EQUIPMENT INSPECTED

State Number: 19010	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2500	Manuf: KONE	Speed: 125
Landings: 3	Installed: 10/18/2000	Rope Size:
Volts: 480	Complied: 10/26/2000	Entrances: 2
OWNER	OCCUPANT	
ASHE CO BOARD OF COMMERCE	ASHE CO GOVERNMENT COMPLEX	
150 GOV'T CIRCLE STE 2500	150 GOV'T CIRCLE	
JEFFERSON, NC, 28640	JEFFERSON, NC, 28640	

INSPECTION INFORMATION

Inspection Date 11/26/2013	Type Inspection Routine	Certificate Status Re-issued	Inspector 7 - Hoffman	County ASHE
-------------------------------	----------------------------	---------------------------------	--------------------------	----------------

5

VIOLATIONS

NONE

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: ANGIE EGGARS 336-846-5508

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ASHE CO BOARD OF COMMERCE
150 GOV'T CIRCLE STE 2500
JEFFERSON, NC, 28640