



INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
13345-48-3332
State Number
15399

EQUIPMENT INSPECTED

State Number: 15399	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 4500	Manuf: OTIS	Speed: 125
Landings: 3	Installed: 06/22/1994	Rope Size:
Volts: 480	Complied: 08/19/1994	Entrances: 1
OWNER	OCCUPANT	
PROGRESS ENERGY	PROGRESS ENERGY - MTCE. BLDG.	
8470 RIVER ROAD SE	8470 RIVER ROAD SE	
SOUTHPORT, NC, 28461	SOUTHPORT, NC, 28461	

INSPECTION INFORMATION

Inspection Date 12/11/2013	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

- 8.11.1.6 Provide a metal with test date, the requirement number requiring the test, and the name of the person or firm performing the test inside the machine room for all Categories 3, 5 tests for electric elevators and 1,3, 5 tests for hydraulic elevators
- 8.6.4.7.1 Clean the elevator pit.

Items must be corrected by: 01/10/2014

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: SUSIE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

PROGRESS ENERGY
8470 RIVER ROAD SE
SOUTHPORT, NC, 28461