



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
13345-48-4056
State Number
14768

EQUIPMENT INSPECTED

State Number: 14768	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 4000	Manuf: THYSSEN KRUPP	Speed: 100
Landings: 2	Installed: 08/10/1992	Rope Size:
Volts: 480	Complied: 08/10/1992	Entrances: 1
OWNER	OCCUPANT	
PROGRESS ENERGY	PROGRESS ENERGY - OFFICE BLDG.	
8470 RIVER ROAD SE	8470 RIVER ROAD SE	
SOUTH PORT, NC, 28461	SOUTH PORT, NC, 28461	

INSPECTION INFORMATION

Inspection Date 12/11/2013	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

- 8.6.5.9 Relief-Valve Setting. The relief-valve adjustment shall be examined to ensure that the seal is intact. If the relief-valve seal is not intact, checks shall be conducted in accordance with 8.11.3.2.1. [SEAL MISSING].
- 2.2.5.1 Put the pit lights in proper working order.
- 8.6.4.7.1 Clean the elevator pit.

Items must be corrected by: 01/10/2014

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: SUSIE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

PROGRESS ENERGY
8470 RIVER ROAD SE
SOUTH PORT, NC, 28461