



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**13350-48-1452**  
State Number  
**12252**

EQUIPMENT INSPECTED

State Number: <b>12252</b>	Type of Unit: Passenger	Floor to Floor: 1 to -
Capacity: 4000	Manuf: SOUTHERN	Speed: 100
Landings: 5	Installed: 11/03/1987	Rope Size: 5/8
Volts: 480	Complied: 06/12/2006	Entrances: 1
OWNER	OCCUPANT	
CAPITAL POWER CORP.	CAPITAL POWER CORP.	
PO BOX 10836	1281 POWERHOUSE DR.	
SOUTHPORT, NC, 28461	SOUTHPORT, NC, 28461	

INSPECTION INFORMATION

Inspection Date 12/16/2013	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

8.6.4.8.1	Clean the elevator machine room.
2.2.5.1	Put the pit lights in proper working order.
8.6.4.7.4	Remove the water from the pit floor.
N/A	CLEAN BRUSH RIGGINGS ON GENERATOR AND MAIN MOTOR.

Items must be corrected by: 01/15/2014

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: TOM

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

CAPITAL POWER CORP.  
PO BOX 10836  
SOUTHPORT, NC, 28461