N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
**13354-36-4673**
State Number
**24228**

## EQUIPMENT INSPECTED

State Number: **24228**
Capacity: 2000
Landings: 3
Volts: 208

Type of Unit: Passenger
Manuf: OTIS
Installed: 10/31/2006
Complied: 10/31/2006

Floor to Floor: 1 to 3
Speed: 125
Rope Size: 0
Entrances: 1

OWNER
ELON UNIVERSITY
803 HAGGARD AVENUE
ELON, NC, 27244

OCCUPANT
OAKS BUILDING (B)
1002 ELON ACORN DRIVE
ELON, NC, 27244

## INSPECTION INFORMATION

| Inspection Date | Type Inspection | Certificate Status | Inspector | County |
|---|---|---|---|---|
| 12/20/2013 | Routine | Re-issued | 36 - Kirkman | ALAMANCE |

1

## VIOLATIONS

None found

Elevator Name: BUILDING (B)

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: Bob 336.278.2000 Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
ELON UNIVERSITY
803 HAGGARD AVENUE
ELON, NC, 27244