



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
13361-54-5041
State Number
27753

EQUIPMENT INSPECTED

State Number: 27753	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 4000	Manuf: ABELL	Speed: 75
Landings: 2	Installed: 11/21/2011	Rope Size:
Volts: 480	Complied:	Entrances: 1
OWNER	OCCUPANT	
STATE OF NCDOC	BERTIE CORRECTIONAL / TAN WING	
831 MORGAN STREET	218 COOPER HILL ROAD	
RALEIGH, NC, 27603	WINDSOR, NC, 27983	

INSPECTION INFORMATION

Inspection Date 12/27/2013	Type Inspection Routine	Certificate Status Re-issued	Inspector 54 - Green	County BERTIE
-------------------------------	----------------------------	---------------------------------	-------------------------	------------------

8

VIOLATIONS

8.11.3.2.1	Perform the annual relief valve test
8.6.1.4.1[a]	Properly document maintenance records

Items must be corrected by: 01/26/2014

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: CHARLES GURGANUS 252 794 8650

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

STATE OF NCDOC
831 MORGAN STREET
RALEIGH, NC, 27603