



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
14007-36-1430
State Number
14573

EQUIPMENT INSPECTED

State Number: 14573	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2000	Manuf: THYSSEN KRUPP	Speed: 100
Landings: 3	Installed: 07/07/1992	Rope Size:
Volts: 208	Complied: 07/17/1992	Entrances: 1
OWNER	OCCUPANT	
ELON UNIVERSITY	ELON UNIV / CARLTON HALL	
803 HAGGARD AVENUE	105 E HAGGARD AVE	
ELON, NC, 27244	ELON, NC, 27244	

INSPECTION INFORMATION

Inspection Date 01/07/2014	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

1

VIOLATIONS

Elevator Name: CARLTON HALL

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainance with current codes.

Violations pointed out to: Bob Willis 336.278.2000

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ELON UNIVERSITY
803 HAGGARD AVENUE
ELON, NC, 27244