N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
14016-16-1744
State Number
N7.4

EQUIPMENT INSPECTED

State Number: **N7.4**
Capacity: 2000
Landings: 4
Volts: 220

Type of Unit: Passenger
Manuf: SOUTHERN
Installed: 06/03/1975
Complied: 06/03/1975

Floor to Floor: B to 3
Speed: 300
Rope Size: 1/2
Entrances: 1

OWNER
CITY OF WASHINGTON
PO BOX 1988
WASHINGTON, NC, 27889

OCCUPANT
WASHINGTON MUNICIPAL BLDG
100 SECOND ST
WASHINGTON, NC, 27889

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
01/16/2014	Routine	Re-issued	16 - Moore	BEAUFORT

7

VIOLATIONS

8.11.2.2.2 Perform an annual no load safety test and provide proper tags.

Items must be corrected by: 02/15/2014

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: William Conner

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
CITY OF WASHINGTON
PO BOX 1988
WASHINGTON, NC, 27889