



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
14016-17-4458
State Number
16051

EQUIPMENT INSPECTED

State Number: 16051	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 3500	Manuf: US ELEVATOR	Speed: 125
Landings: 3	Installed: 03/20/1996	Rope Size:
Volts: 208	Complied: 03/20/1996	Entrances: 1
OWNER	OCCUPANT	
ARDEN PRESBYTERIAN CHURCH	ARDEN PRESBYTERIAN CHURCH	
2215 HENDERSONVILLE RD	2215 HENDERSONVILLE RD	
ARDEN, NC, 28704	ARDEN, NC, 28704	

INSPECTION INFORMATION

Inspection Date 01/16/2014	Type Inspection Routine	Certificate Status Re-issued	Inspector 17 - White	County BUNCOMBE	11 A
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------	------

VIOLATIONS

note no violations.

Items must be corrected by: 01/16/2014

Elevator Name: 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: office 828-864-1447

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ARDEN PRESBYTERIAN CHURCH
2215 HENDERSONVILLE RD
ARDEN, NC, 28704