



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
14023-17-0136
State Number
9563

EQUIPMENT INSPECTED

| | | |
|---------------------------|---------------------------|------------------------|
| State Number: 9563 | Type of Unit: Passenger | Floor to Floor: 1 to 3 |
| Capacity: 2000 | Manuf: ASHEVILLE | Speed: 125 |
| Landings: 3 | Installed: 05/05/1980 | Rope Size: |
| Volts: 480 | Complied: 06/04/1980 | Entrances: 1 |
| OWNER | OCCUPANT | |
| AB TECHNICAL COLLEGE | AB TECHNICAL COLLEGE/ ELM | |
| 340 VICTORIA RD | 340 VICTORIA RD | |
| ASHEVILLE, NC, 28801 | ASHEVILLE, NC, 28801 | |

INSPECTION INFORMATION

| | | | | | |
|-------------------------------|----------------------------|---------------------------------|-------------------------|--------------------|------|
| Inspection Date 01/23/2014 | Type Inspection Routine | Certificate Status Re-issued | Inspector 17 - White | County BUNCOMBE | 11 A |
|-------------------------------|----------------------------|---------------------------------|-------------------------|--------------------|------|

VIOLATIONS

8.6.5.5.1 Where valves and cylinders use packing glands or seals, they shall be examined and maintained to prevent excessive loss of fluid.

Items must be corrected by: 02/22/2014

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Mary Rice 828-254-1921

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

AB TECHNICAL COLLEGE
340 VICTORIA RD
ASHEVILLE, NC, 28801