



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
14023-17-4147
State Number
9951

EQUIPMENT INSPECTED

State Number: 9951	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2000	Manuf: SOUTHERN	Speed: 125
Landings: 2	Installed: 06/23/1981	Rope Size:
Volts: 230	Complied: 06/23/1981	Entrances: 1

OWNER

AB TECH COLLEGE /BIRCH BLDG
340 VICTORIA RD
ASHEVILLE, NC, 28801

OCCUPANT

AB TECH COLLEGE /BIRCH BLDG
340 VICTORIA RD
ASHEVILLE, NC, 28801

INSPECTION INFORMATION

Inspection Date 01/23/2014	Type Inspection Routine	Certificate Status Re-issued	Inspector 17 - White	County BUNCOMBE	11 A
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------	------

VIOLATIONS

8.6.4 Repair car door photo eyes.

Items must be corrected by: 02/22/2014

Elevator Name: birch

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Marty Rice 828-254-1921

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

AB TECH COLLEGE /BIRCH BLDG
340 VICTORIA RD
ASHEVILLE, NC, 28801