



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
14035-36-5552
State Number
23100

EQUIPMENT INSPECTED

State Number: 23100	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2500	Manuf: OTIS	Speed: 100
Landings: 3	Installed: 06/06/2005	Rope Size:
Volts: 208	Complied: 06/06/2005	Entrances: 1

OWNER

SLATTER MNG SERVICES INC
4425 - G WALKER AVE
GREENSBORO, NC, 27407

OCCUPANT

WINDMERE CONDOS #2
3010 WINSTON DRIVE
BURLINGTON, NC, 27215

INSPECTION INFORMATION

Inspection Date 02/04/2014	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

1

VIOLATIONS

none found

Elevator Name: WANDA 336-272-0642

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: TINA TILLMAN 336-272-0641

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

SLATTER MNG SERVICES INC
4425 - G WALKER AVE
GREENSBORO, NC, 27407