



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
14037-36-0990
State Number
15315

EQUIPMENT INSPECTED

State Number: 15315	Type of Unit: Passenger	Floor to Floor: LL to 3
Capacity: 4500	Manuf: KONE	Speed: 350
Landings: 4	Installed: 04/14/1995	Rope Size: 5/8
Volts: 480	Complied: 07/11/1995	Entrances: 1
OWNER		OCCUPANT
ALAMANCE REGIONAL MEDICAL CENTER		ALAMANCE REGIONAL MEDICAL CTR
PO BOX 202		1230 HUFFMAN MILL RD
BURLINGTON, NC, 27216		BURLINGTON, NC, 27215

INSPECTION INFORMATION

Inspection Date 02/06/2014	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

VIOLATIONS

8.6.4.8.1	Floors and machinery spaces shall be kept free of water, dirt, rubbish, oil, and grease. Around machine and floor.
8.6.4.7.1	Clean the elevator pit.
8.6.1.2.1	Provide a written maintenance program.
8.6.10.1	Update the monthly fire service log.
8.11.2.2.2	Perform the annual no load safety test
8.6.4.9	Clean the elevator car top. Sticky oil residue

Items must be corrected by: 03/08/2014

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Curtis 336-538-7776

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ALAMANCE REGIONAL MEDICAL CENTER
PO BOX 202
BURLINGTON, NC, 27216