



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
14038-36-5346
State Number
20282

EQUIPMENT INSPECTED

State Number: 20282	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 95
Landings: 2	Installed: 08/08/2001	Rope Size:
Volts: 480	Complied: 08/09/2001	Entrances: 1
OWNER	OCCUPANT	
ALAMANCE REGIONAL MEDICAL	GENERAL SERVICES	
1230 HUFFMAN MILL RD	3050 GRAND OAKS BLVD	
BURLINGTON, NC, 27320	BURLINGTON, NC, 27320	

INSPECTION INFORMATION

Inspection Date 02/07/2014	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

1

VIOLATIONS

8.6.10.1	Update the monthly fire service log.
8.6.4.7.1	Clean the elevator pit.
8.6.1.2.1	Provide a written maintenance program.
8.11.2.2.2	Perform the annual no load safety test

Items must be corrected by: 03/09/2014

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Curtis 336-538-7776

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ALAMANCE REGIONAL MEDICAL
1230 HUFFMAN MILL RD
BURLINGTON, NC, 27320