



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
14048-36-2971
State Number
1442

EQUIPMENT INSPECTED

State Number: 1442	Type of Unit: Passenger	Floor to Floor: G to 4
Capacity: 4000	Manuf: ASK	Speed: 200
Landings: 5	Installed: 02/01/1951	Rope Size: 5/8
Volts: 208	Complied: 09/23/1997	Entrances: 1
OWNER	OCCUPANT	
ALAMANCE CO	HUMAN SERVICES FACILITY	
124 W ELM ST	319 N GRAHAM / HOPEDALE RD	
GRAHAM, NC, 27253	BURLINGTON, NC, 27217	

INSPECTION INFORMATION

Inspection Date 02/17/2014	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

1

VIOLATIONS

- 2.27.1.1.2 Put the in car emergency telephone in proper working order.
- 8.6.4.9 Clean the elevator car top.
- 8.6.4.7.1 Clean the elevator pit.
- 8.6.3.2.2 Suspension means, compensation means, and governor ropes shall be replaced when they no longer conform to the requirements of ASME A17.6.
 - 8.6.3.2.1. For steel wire rope, ASME A17.6, Section 1.10 shall apply.

Items must be corrected by: 03/19/2014

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Carmen Moran 336-2666303

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ALAMANCE CO
124 W ELM ST
GRAHAM, NC, 27253