



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
14049-16-1574
State Number
2973

EQUIPMENT INSPECTED

State Number: 2973	Type of Unit: Passenger	Floor to Floor: 1 to 4
Capacity: 4000	Manuf: OTIS	Speed: 200
Landings: 4	Installed: 10/18/1957	Rope Size: 5/8
Volts: 208	Complied: 10/24/2002	Entrances: 1
OWNER	OCCUPANT	
VIDANT HEALTH	VIDANT BEAUFORT COUNTY HOSPITAL	
PO BOX 6028	628 E 12TH ST	
GREENVILLE, NC, 27835	WASHINGTON, NC, 27889	

INSPECTION INFORMATION

Inspection Date 02/18/2014	Type Inspection Routine	Certificate Status Re-issued	Inspector 16 - Moore	County BEAUFORT
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

7

VIOLATIONS

2.25.2 Put the directional limit device in proper working order. Properly Adjust down normal to stop before engaging final limit

Items must be corrected by: 03/20/2014

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Timmy / Maintenance Chief

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

VIDANT HEALTH
PO BOX 6028
GREENVILLE, NC, 27835