



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

### INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**14049-16-4553**  
State Number  
**6120**

### EQUIPMENT INSPECTED

State Number: <b>6120</b>	Type of Unit: Passenger	Floor to Floor: 1 to 4
Capacity: 4000	Manuf: OTIS	Speed: 200
Landings: 4	Installed: 07/28/1968	Rope Size: 5/8
Volts: 208	Complied: 01/07/1969	Entrances: 1
OWNER	OCCUPANT	
VIDANT HEALTH	VIDANT BEAUFORT COUNTY HOSPITAL	
PO BOX 6028	628 E 12TH ST	
GREENVILLE, NC, 27835	WASHINGTON, NC, 27889	

### INSPECTION INFORMATION

Inspection Date 02/18/2014	Type Inspection Routine	Certificate Status Re-issued	Inspector 16 - Moore	County BEAUFORT
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

7

### VIOLATIONS

8.6.4.13.1[h] Properly maintain sills and bottom guides, fastenings, condition, and engagement. Put proper strenght shoe on 3rd floor door

8.6.4.13.1[g] Properly maintain/ replace astragals and resilient members, door space guards, and sight guards, where required. Tighten sight guard on 3rd floor

8.11.2.2.2 Perform an annual no load safety test and provide proper tags.

8.6.3.2.1 Replace Hoisting ropes

Items must be corrected by: 03/20/2014

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: Timmy / Maintenance Chief

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

VIDANT HEALTH  
PO BOX 6028  
GREENVILLE, NC, 27835