



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
14051-36-0566
State Number
6590

EQUIPMENT INSPECTED

State Number: 6590	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 3500	Manuf: SOUTHERN	Speed: 75
Landings: 3	Installed: 06/23/1970	Rope Size:
Volts: 480	Complied: 07/01/2003	Entrances: 2
OWNER	OCCUPANT	
ALAMANCE CO SCHOOLS	CUMMINGS SENIOR HIGH SCHOOL	
1712 VAUGHAN RD	2200 MEBANE ST	
BURLINGTON, NC, 27217	BURLINGTON, NC, 27217	

INSPECTION INFORMATION

Inspection Date 02/20/2014	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

VIOLATIONS

- 8.11.2.3.1 Provide the annual no load test.
- 2.26.12 Provide Braille where needed. . Door close braille.
- 8.6.10.1 Update the monthly fire service log.
- 2.14.7.1.3 Put the in car emergency light in working order. LOCATE AND LABEL BREAKER!
- 8.6.4.7.1 Clean the elevator pit.
- 8.6.5.7 Provide an oil usage log in the machine room recording the quantity of hydraulic fluid added to the system and emptied from leakage catch pan and containers.
- 2.27.1.1.2 Put the in car emergency telephone in proper working order.
- 8.6.1.2.1 Provide a written maintenance program.

Items must be corrected by: 03/02/2014

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: mr blsackwell 336-567-0987

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ALAMANCE CO SCHOOLS
1712 VAUGHAN RD
BURLINGTON, NC, 27217