



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
14055-36-578
State Number
22766

EQUIPMENT INSPECTED

State Number: 22766	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: OTIS	Speed: 100
Landings: 2	Installed: 02/07/2005	Rope Size:
Volts: 480	Complied: 02/07/2005	Entrances: 1
OWNER	OCCUPANT	
S P M INVESTMENTS, LLC	CAROLINA NUCLEAR MEDICINE	
2921 CROUSE LANE	2921 CROUSE LANE	
BURLINGTON, NC, 27215	BURLINGTON, NC, 27215	

INSPECTION INFORMATION

Inspection Date 02/24/2014	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

1

VIOLATIONS

none found

Elevator Name: DR. MORAYATI

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: DR. MORAYATI 336-634-1400

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

S P M INVESTMENTS, LLC
2921 CROUSE LANE
BURLINGTON, NC, 27215