N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
14063-48-5236
State Number
19579

EQUIPMENT INSPECTED

State Number: **19579**
Capacity: 2000
Landings: 3
Volts: 240

Type of Unit: Passenger
Manuf: CANTON
Installed: 02/05/2001
Complied: 02/05/2001

Floor to Floor: G to 2
Speed: 100
Rope Size:
Entrances: 1

OWNER
LAWRENCE COASTAL REAL ESTATE
5003 O'QUINN BLVD.
SOUTHPORT, NC, 28461

OCCUPANT
SOUTH PORT CONDOS BLDG.#1
606 W BROWN ST
SOUTHPORT, NC, 28461

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
03/04/2014	Routine	Re-issued	48 - Martin	BRUNSWICK

10

VIOLATIONS

2.15.2 Replace the cracked, worn, or missing car guides.

Items must be corrected by: 04/03/2014

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
LAWRENCE COASTAL REAL ESTATE
5003 O'QUINN BLVD.
SOUTHPORT, NC, 28461