N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
14063-52-3987
State Number
13850

EQUIPMENT INSPECTED

State Number: **13850**
Capacity: 2100
Landings: 2
Volts: 208

Type of Unit: Passenger
Manuf: THYSSEN KRUPP
Installed: 10/22/1990
Complied: 12/12/1990

Floor to Floor: 1 to 2
Speed: 100
Rope Size: 0
Entrances: 1

OWNER
AVERY COUNTY
P.O. BOX 640
NEWLAND, NC, 28657

OCCUPANT
AVERY COUNTY OFFICE BLDG.
175 LINVILLE STREET
NEWLAND, NC, 28657

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County	
03/04/2014	Routine	Re-issued	52 - Sosebee	AVERY	6

VIOLATIONS

5.1.21.1	Put the in car alarm bell in working order.
2.14.7.1.3	Put the in car emergency light in working order.
8.6	Provide proper clearance between hoistway entrance and elevator cab door. (Restrictor or clutch dragging fascia.)

Items must be corrected by: 04/03/2014

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: Avery county 828-733-8259

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
AVERY COUNTY
P.O. BOX 640
NEWLAND, NC, 28657