



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**14064-52-3010**  
State Number  
**22268**

EQUIPMENT INSPECTED

State Number: <b>22268</b>	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2500	Manuf: KONE	Speed: 100
Landings: 3	Installed: 03/16/2004	Rope Size: 0
Volts: 208	Complied: 03/16/2004	Entrances: 1
OWNER	OCCUPANT	
NORTHWESTERN REGIONAL HOUSING	ELK PARK APARTMENTS	
P.O. BOX 2510	256 ELK PARK SCHOOL ROAD	
BOONE, NC, 28607	ELK PARK, NC, 28622	

INSPECTION INFORMATION

Inspection Date 03/05/2014	Type Inspection Routine	Certificate Status Re-issued	Inspector 52 - Sosebee	County AVERY
-------------------------------	----------------------------	---------------------------------	---------------------------	-----------------

6

VIOLATIONS

5.1.21.1	Put the in car alarm bell in working order.
2.14.7.1.3	Put the in car emergency light in working order.

Items must be corrected by: 04/04/2014

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Woody 828-733-1546

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

NORTHWESTERN REGIONAL HOUSING  
P.O. BOX 2510  
BOONE, NC, 28607