N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
14065-52-4885
State Number
28677

EQUIPMENT INSPECTED

State Number: **28677**
Capacity: 2500
Landings: 2
Volts: 208

Type of Unit: Passenger
Manuf: SCHINDLER
Installed: 01/02/2013
Complied:

Floor to Floor: 1 to 2
Speed: 100
Rope Size:
Entrances: 1

OWNER
LINVILLE COVE LIMITED PARTNERS
507 LINVILLE STREET
NEWLAND, NC, 28657

OCCUPANT
LINVILLE COVE APARTMENTS
507 LINVILLE STREET
NEWLAND, NC, 28657

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
03/06/2014	Routine	Re-issued	52 - Sosebee	AVERY

6

VIOLATIONS

2.12.5 Put the car door restricting device in proper working order.

Items must be corrected by: 04/05/2014

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: Herb 828-387-0878 Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
LINVILLE COVE LIMITED PARTNERS
507 LINVILLE STREET
NEWLAND, NC, 28657