



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**14070-52-3961**  
State Number  
**21159**

EQUIPMENT INSPECTED

State Number: <b>21159</b>	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 4500	Manuf: THYSSEN KRUPP	Speed: 125
Landings: 2	Installed: 11/17/2003	Rope Size: 0
Volts: 480	Complied: 11/17/2003	Entrances: 1
OWNER N.C. DEPARTMENT OF CORRECTIONS 831 WEST MORGAN STREET RALEIGH, NC, 27603		OCCUPANT ALEXANDER CORRECTIONAL 633 OLD LANDFILL RD TAYLORSVILLE, NC, 28681

INSPECTION INFORMATION

Inspection Date 03/11/2014	Type Inspection Routine	Certificate Status Re-issued	Inspector 52 - Sosebee	County ALEXANDER
-------------------------------	----------------------------	---------------------------------	---------------------------	---------------------

2

VIOLATIONS

- 8.6.4.7.1 Clean the elevator pit.
- 8.6.10.1 Perform a monthly firefighters Phase 1 and 2 test with the key switches and a minimum one floor run. Document test results with availability to inspector.
- 2.9.1 Assign identification (numbers or letters) to the equipment where required. ( controller, car top and main floor door frame.)

Items must be corrected by: 04/10/2014

Elevator Name: # J

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: NC DPS 828-632-1331

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

N.C. DEPARTMENT OF CORRECTIONS  
831 WEST MORGAN STREET  
RALEIGH, NC, 27603