

N C Department of Labor Elevator Bureau 1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in any correspondence relating to your equipment www.nclabor.com/elevator.htm 919-707-7927

Report Number 14070-52-5697 State Number 21160

2

		919-707-7927			
		EQUIPMENT INSPECTED			
ate Number: 21160	Type of Unit: Passenger		Floor to Floor: 1 to 2		
apacity: 4500			Speed: 125		
andings: 2 Installed: 11/17/2003		2003	Rope Size: 0		
Volts: 480 Complied: 11/17/2003		7/2003	Entrances: 1		
OWNER		OCCU	JPANT		
N.C. DEPTARTMENT OF CORRECTIONS		ALEX	ALEXANDER CORRECTIONAL		
831 WEST MORGAN STREET		633 O	633 OLD LANDFILL ROAD		
RALEIGH, NC, 27603		TAYLORSVILLE, NC, 28681			
	 Iì	NSPECTION INFORMATION			
Inspection Date Type Inspection 03/11/2014 Routine		Certificate Status Re-issued	Inspector 52 - Sosebee	County ALEXANDER	
		VIOLATIONS			
5.1.21.1 Put the in car alarm	bell in working order.				
Items must be corrected by: 04/10/2014			Elevator Name: # L		
otify the Elevator Bureau in womplainace with current codes	vriting on Corrected Violations Form	n when the following corrections	s have been made in order to b	oring your equipment into	
Violations pointed out to: NC DPS 828-632-1331			Inspector		
THIS IS NOT AN INVOICE	To make changes to the invoice mailing address please call: 919-733-0372				
	N.C. DEPTARTMENT OF CORRECTIONS An invoice will be mailed to: 831 WEST MORGAN STREET RALEIGH, NC, 27603				