



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
14073-52-1754
State Number
H2442

EQUIPMENT INSPECTED

State Number: H2442	Type of Unit: Hand Lift	Floor to Floor: 1 to 2
Capacity: 750	Manuf: GARAVENTA	Speed: 30
Landings: 2	Installed: 02/21/2013	Rope Size:
Volts: 230	Complied:	Entrances: 2
OWNER		OCCUPANT
BANNER ELK VISTA PROPERTIES LLC		THE VISTAS
PO BOX 2074		325 PENNY LANE
BANNER ELK, NC, 28604		BANNER ELK, NC, 28604

INSPECTION INFORMATION

Inspection Date 03/14/2014	Type Inspection Routine	Certificate Status Re-issued	Inspector 52 - Sosebee	County AVERY
-------------------------------	----------------------------	---------------------------------	---------------------------	-----------------

6

VIOLATIONS

A 18.1	Put the machine room light in proper working order.
A 18.1	Take steps to allow proper stopping accuracy at top floor.
A 18.1	Program the in car emergency phone to building address and lift number.

Items must be corrected by: 04/13/2014

Elevator Name: 3

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: JP 828-964-2458

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

BANNER ELK VISTA PROPERTIES LLC
PO BOX 2074
BANNER ELK, NC, 28604