



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**14073-52-5163**  
State Number  
**H2509**

EQUIPMENT INSPECTED

State Number: <b>H2509</b>	Type of Unit: Hand Lift	Floor to Floor: 1 to 2
Capacity: 750	Manuf: GARAVENTA	Speed: 30
Landings: 2	Installed: 12/11/2013	Rope Size: 3/8
Volts: 230	Complied: 12/11/2013	Entrances: 2
OWNER	OCCUPANT	
BANNER ELK VISTA PROPERTIES	VISTAS @ BANNER ELK #5	
PO BOX 2074	325 PENNY LANE	
BANNER ELK, NC, 28604	BANNER ELK, NC, 28604	

INSPECTION INFORMATION

Inspection Date 03/14/2014	Type Inspection Routine	Certificate Status Re-issued	Inspector 52 - Sosebee	County AVERY
-------------------------------	----------------------------	---------------------------------	---------------------------	-----------------

6

VIOLATIONS

A 18.1 Take steps to keep the machine room access door closed and locked at all times.  
A 18.1 Repair leak on jack and clean all oil from hoistway and pit apparatus.

Items must be corrected by: 04/13/2014

Elevator Name: # 5

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: JP 828-964-2458

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

BANNER ELK VISTA PROPERTIES  
PO BOX 2074  
BANNER ELK, NC, 28604