N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
14076-48-3638
State Number
19014

EQUIPMENT INSPECTED

State Number: **19014**
Capacity: 3000
Landings: 4
Volts: 208

Type of Unit: Passenger
Manuf: THYSSEN KRUPP
Installed: 03/15/2000
Complied: 03/15/2000

Floor to Floor: G to 3
Speed: 125
Rope Size:
Entrances: 1

OWNER
CAM
P.O. BOX 8126
OCEAN ISLE BEACH, NC, 28469

OCCUPANT
ISLANDER RESORT
#1 BECKY ST
OCEAN ISLE BEACH, NC, 28469

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
03/17/2014	Routine	Re-issued	48 - Martin	BRUNSWICK

10

VIOLATIONS

2.27.1.1.2 Put the in car emergency telephone in proper working order.

Items must be corrected by: 04/16/2014

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
CAM
P.O. BOX 8126
OCEAN ISLE BEACH, NC, 28469