



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
14077-36-5132
State Number
5977

EQUIPMENT INSPECTED

State Number: 5977	Type of Unit: Freight	Floor to Floor: B to 1
Capacity: 2000	Manuf: SOUTHERN	Speed: 60
Landings: 2	Installed: 10/18/1967	Rope Size:
Volts: 220	Complied: 07/12/1968	Entrances: 2
OWNER	OCCUPANT	
GRAHAM DYING & FINISHING	GRAHAM DYEING & FINISHING	
PO BOX 2857	110 N BROAD ST	
BURLINGTON, NC, 27215	BURLINGTON, NC, 27215	

INSPECTION INFORMATION

Inspection Date 03/18/2014	Type Inspection Routine	Certificate Status Not Issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------	----------------------------------	---------------------------	--------------------

1

VIOLATIONS

8.6.4.7.4 Take steps to eliminate the accumulation of water on the pit floor and remove same.
8.6 TAKE STEPS TO PLACE ELEVATOR IN PROPER WORKINBG ORDER

Items must be corrected by: 04/17/2014

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: thomas allen 336-228-9981

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

GRAHAM DYING & FINISHING
PO BOX 2857
BURLINGTON, NC, 27215