



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**14078-36-1486**  
State Number  
**13709**

EQUIPMENT INSPECTED

|                            |                         |                        |
|----------------------------|-------------------------|------------------------|
| State Number: <b>13709</b> | Type of Unit: Passenger | Floor to Floor: 1 to 3 |
| Capacity: 4000             | Manuf: THYSSEN KRUPP    | Speed: 80              |
| Landings: 3                | Installed: 09/19/1991   | Rope Size:             |
| Volts: 460                 | Complied: 02/07/1994    | Entrances: 2           |
| OWNER                      | OCCUPANT                |                        |
| LAB CORP                   | LAB CORP                |                        |
| ATTN STEVE THACKER         | 1447 YORK CT            |                        |
| BURLINGTON, NC, 27215      | BURLINGTON, NC, 27215   |                        |

INSPECTION INFORMATION

|                               |                            |                                 |                           |                    |
|-------------------------------|----------------------------|---------------------------------|---------------------------|--------------------|
| Inspection Date<br>03/19/2014 | Type Inspection<br>Routine | Certificate Status<br>Re-issued | Inspector<br>36 - Kirkman | County<br>ALAMANCE |
|-------------------------------|----------------------------|---------------------------------|---------------------------|--------------------|

1

VIOLATIONS

|           |                             |
|-----------|-----------------------------|
| 8.6.4.9   | Clean the elevator car top. |
| 8.6.4.7.1 | Clean the elevator pit.     |

Items must be corrected by: 04/18/2014

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: DAVID STUBBLEFIELD 336-516-1117

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

LAB CORP  
ATTN STEVE THACKER  
BURLINGTON, NC, 27215