



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
14079-48-5375
State Number
21072

EQUIPMENT INSPECTED

State Number: 21072	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2000	Manuf: THYSSEN KRUPP	Speed: 100
Landings: 3	Installed: 05/23/2002	Rope Size:
Volts: 208	Complied: 05/23/2002	Entrances: 1
OWNER	OCCUPANT	
SAGAR PATEL & WES WARD	ECONOLODGE INN & SUITES	
4646 EAST COAST LANE NW	4646 EAST COAST LANE NW	
SHALOTTE, NC, 28470	SHALOTTE, NC, 28470	

INSPECTION INFORMATION

Inspection Date 03/20/2014	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

2.2.2.4	Put the sump pump in proper working order.
8.6.4.7.4	Remove the water from the pit floor.

Items must be corrected by: 04/19/2014

Elevator Name: #1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: MGMT

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

SAGAR PATEL & WES WARD
4646 EAST COAST LANE NW
SHALOTTE, NC, 28470