



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
14090-16-5466
State Number
20669

EQUIPMENT INSPECTED

State Number: 20669	Type of Unit: Passenger	Floor to Floor: 1 to 4
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 125
Landings: 4	Installed: 05/15/2002	Rope Size: 0
Volts: 208	Complied:	Entrances: 1
OWNER	OCCUPANT	
ARUN DESAI LODGING ASSOC	HAMPTON INN	
2085 W. 15TH ST.	2085 W. 15TH ST.	
WASHINGTON, NC, 27889	WASHINGTON, NC, 27889	

INSPECTION INFORMATION

Inspection Date 03/31/2014	Type Inspection Routine	Certificate Status Re-issued	Inspector 16 - Moore	County BEAUFORT
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

7

VIOLATIONS

n/a No violations found

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Maintenance

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ARUN DESAI LODGING ASSOC
2085 W. 15TH ST.
WASHINGTON, NC, 27889