



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

### INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**14093-48-4212**  
State Number  
**24780**

### EQUIPMENT INSPECTED

State Number: <b>24780</b>	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2100	Manuf: TKE	Speed: 135
Landings: 3	Installed: 06/27/2007	Rope Size:
Volts: 208	Complied: 06/27/2007	Entrances: 1

#### OWNER

SOUTH HARBOUR STATION  
305 NORTH HOWE STREET  
SOUTHPORT, NC, NC, 28461

#### OCCUPANT

SOUTH HARBOR  
4132 VANESSA DRIVE  
OAK ISLAND, NC, 28429

### INSPECTION INFORMATION

Inspection Date 04/03/2014	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

### VIOLATIONS

8.6.4.7.1	Clean the elevator pit.
2.27.1.1.2	Put the in car emergency telephone in proper working order.
8.6.8.9	Signs. Caution signs shall be provided. Damaged or missing signs shall be replaced. [1ST. & 3RD. FLS.]

Items must be corrected by: 05/03/2014

Elevator Name: # 2

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

SOUTH HARBOUR STATION  
305 NORTH HOWE STREET  
SOUTHPORT, NC, NC, 28461