N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
14093-48-5887
State Number
26609

EQUIPMENT INSPECTED

State Number: **26609**
Capacity: 2000
Landings: 2
Volts: 208

Type of Unit: Passenger
Manuf: OTIS
Installed: 02/10/2009
Complied: 02/10/2009

Floor to Floor: 1 to 2
Speed: 125
Rope Size:
Entrances: 1

OWNER
TONY MICHAELAKIS,D.D.S.
3071 SOUTHPORT SUPPLY RD
BOLIVIA, NC, 28422

OCCUPANT
COASTAL COSMETIC DENISTRY
3071 SOUTHPORT SUPPLY RD
BOLIVIA, NC, 28422

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County	
04/03/2014	Routine	Re-issued	48 - Martin	BRUNSWICK	10

VIOLATIONS

8.11.2.2.2 Perform the annual no load safety test

Items must be corrected by: 05/03/2014

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: TERESA

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
TONY MICHAELAKIS,D.D.S.
3071 SOUTHPORT SUPPLY RD
BOLIVIA, NC, 28422