



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
14098-17-2054
State Number
10681

EQUIPMENT INSPECTED

| | | |
|----------------------------|-------------------------|------------------------|
| State Number: 10681 | Type of Unit: Passenger | Floor to Floor: 1 to 6 |
| Capacity: 2500 | Manuf: ASHEVILLE | Speed: 150 |
| Landings: 6 | Installed: 03/09/1984 | Rope Size: 0 |
| Volts: 460 | Complied: 03/09/1984 | Entrances: 1 |
| OWNER | OCCUPANT | |
| AMBICA LLC | HOLIDAY INN ASHEVILLE | |
| PO BOX 2470 | 435 SMOKEY PARK HIGHWAY | |
| CANDLER, NC, 28715 | ASHEVILLE, NC, 28806 | |

INSPECTION INFORMATION

| | | | | | |
|-------------------------------|----------------------------|---------------------------------|-------------------------|--------------------|------|
| Inspection Date 04/08/2014 | Type Inspection Routine | Certificate Status Re-issued | Inspector 17 - White | County BUNCOMBE | 11 A |
|-------------------------------|----------------------------|---------------------------------|-------------------------|--------------------|------|

VIOLATIONS

2.14.7.1.3 Put the in car emergency light in working order.

Items must be corrected by: 05/08/2014

Elevator Name: 3

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Jackie

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

AMBICA LLC
PO BOX 2470
CANDLER, NC, 28715