



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
14104-48-4521
State Number
18812

EQUIPMENT INSPECTED

State Number: 18812	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2500	Manuf: OTIS	Speed: 125
Landings: 3	Installed: 06/22/2000	Rope Size:
Volts: 208	Complied: 06/22/2000	Entrances: 1
OWNER	OCCUPANT	
C 3 INVESTMENTS OF NC	HAMPTON INN	
5181 SOUTHPORT/SUPPLY RD.	5181 SOUTH PORT / SUPPLY RD	
SOUTHPORT, NC, 28461	SOUTH PORT, NC, 28461	

INSPECTION INFORMATION

Inspection Date 04/14/2014	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

- 2.15.2 Replace the cracked, worn, or missing car guides. [SCREW DRIVER WEDGED IN GUIDE BRACKET UNDER CAR].
2.27.3.3 Put the Phase II fire service feature in proper working order. [CALL CANCEL INOPERATIVE].

Items must be corrected by: 05/14/2014

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: ELEANOR ERICKSON

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

C 3 INVESTMENTS OF NC
5181 SOUTHPORT/SUPPLY RD.
SOUTHPORT, NC, 28461