



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
14106-48-2033
State Number
26346

EQUIPMENT INSPECTED

State Number: 26346	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: SCHINDLER	Speed: 125
Landings: 2	Installed: 01/28/2009	Rope Size:
Volts: 208	Complied:	Entrances: 1
OWNER	OCCUPANT	
CITY OF BOILING SPRING LAKES	BOILING SPRING LAKES TOWN HALL	
9 E BOILING SPRING ROAD	9 E BOILING SPRINGS ROAD	
BOILING SPRING LAKES, NC, 28461	BOILING SPRING LAKES, NC, 28461	

INSPECTION INFORMATION

Inspection Date 04/16/2014	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

2.27.1.1.2 Put the in car emergency telephone in proper working order.

Items must be corrected by: 05/16/2014

Elevator Name: #1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: S. HARTMAN

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

CITY OF BOILING SPRING LAKES
9 E BOILING SPRING ROAD
BOILING SPRING LAKES, NC, 28461